






Blockfundament / block foundation



Container	A	B	C	D
2520	1506	1900	2410	1928
4320	3900	1341	4410	1928
4330	3900	1341	4410	1928
6320	5900	1341	6410	1928
6330	5900	1341	6410	1928

Plattenfundament / plate foundation



Container	E	F
2520	2800	2650
4320	4800	2650
4330	4800	3150
6320	6800	2650
6330	6800	3150

Foundation notes

- The foundation to be provided by the customer must be designed so that the specified loads are safely discharged.
- The selection of concrete in terms of load-bearing capacity, serviceability and durability according to DIN EN 206 shall be determined by the planner in accordance with local requirements and conditions.
- Exemplary foundation:
 - Underlying ground pressure 200kN/m².
 - concrete C25/30 XF2, XC2 for concrete corrosion with moderate water saturation, de-icing agent and reinforcement corrosion wet, rarely dry.
 - Reinforcing steel Q188A, designed for construction.
- Flatness tolerance:
 - designed according to DIN 18202:2013-04 Table 3, ready to use.
 - Measuring point distance 1m.
 - Limit values for dimensional and angular deviations according to DIN 18202:2013-04 Table 1 and Table 2.

Fundamenthinweise

- Das baustellig zu entstellende Fundament ist so auszuliegen, dass die angegebenen Lasten sicher eingeleitet werden.
Die Auswahl des Beton bezüglich Tragfähigkeit, Gebrauchtauglichkeit und Dauerhaftigkeit nach DIN EN 206 ist vom Planer gemäß der örtlichen Anforderungen und Bedingungen festzulegen.
- Beispielhafte Gründung:
 - Zugrunde gelegte Bodenpressung 200kN/m².
 - Beton C25/30 XF2, XC2 für eine Betonkorrosion mit mäßiger Wassersättigung.
 - Taunittel und eine Bewehrungskorrosion nass, selten trocken.
 - Bewehrungsstahl Q188A, konstruktiv ausgelegt.
- Ebenheitstoleranz:
 - ausgelegt entsprechend DIN 18202:2013-04 Tabelle 3, flächenfertig.
 - Messpunktabstand 1m.
 - Grenzwerte für Maß- und Winkelabweichungen gemäß DIN 18202:2013-04 Tabelle 1 und Tabelle 2.

Version		Changes		Change No.	Date	Info
Projection Method		General Tolerances DIN ISO 2768-mk		Drawing Date		
		Welding Tolerance Classes EN ISO 13920-AE		Revision		
		Thermal Cutting Tolerance ISO 9013:40				
Customer		Document Status		Drawing		
		30		KLOSE		
Project No.		Material		Drawing Date		
		BCR-SAP Material		21.11.19		
				Customer By		
				DAHLHUES		
Special Information		Weight		Release Date		
		12465,39 kg		19.08.2020		
Document No.		Description		Document No.		
DENIOS		MC-Vario Fundament		10000036118		
		A00000000000000000000		sheet 1 of 1		
				A0 DE		